PRODUCT-DETAILS

# XT2H 160 TMA 50-500 3p F F

XT2H 160 TMA 50-500 3p F F



## Información General

| | |
|---|---|
| Extended Product Type | XT2H 160 TMA 50-500 3p F F |
| Product ID | 1SDA067599R1 |
| EAN | 8015644014957 |
| Catalog Description | XT2H 160 TMA 50-500 3p F F |
| Long Description | C.BREAKER TMAX XT2H 160 FIXED THREE-POLE WITH FRONT TERMINALS AND THERMOMAGNETIC RELEASE TMA R 50 I3=250...500 A |

## Clasificación

| | |
|---|---|
| E-Number (Finland) | 3602497 |
| EAN | 8015644014957 |
| Minimum Order Quantity | 1 piece |
| Customs Tariff Number | 85362090 |

## Dimensiones

| | |
|---|---|
| Product Net Width | 90 mm |
| Product Net Height | 130 mm |
| Product Net Depth / Length | 82.5 mm |

| | |
|---|---|
| Product Net Weight | 1.1 kg |

## Información de Embalaje

| | |
|---|---|
| Package Level 1 Units | 1 piece |
| Package Level 1 Width | 130 mm |
| Package Level 1 Height | 208 mm |
| Package Level 1 Depth / Length | 145 mm |
| Package Level 1 Gross Weight | 1.66 kg |
| Package Level 1 EAN | 8015644014957 |

## Ambiente

| | |
|---|---|
| RoHS Status | Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019 |

## Información Adicional

| | |
|---|---|
| Circuit Breaker Type to be Associated | Power Distribution |
| Current Type | AC/DC |
| Electrical Durability | 120 cycles per hour<br>8000 cycle |
| Mechanical Durability | Nr. Operations 240 cycles per hour<br>Nr. Operations 25000 cycle |
| Number of Poles | 3 |
| Opening Time | CB with SOR 15 ms<br>CB with UVR 15 ms |
| Order Multiple | 1 piece |
| Power Loss | at Rated Operating Conditions per Pole 4.09 W |
| Product Main Type | SACE Tmax XT |
| Product Name | Moulded Case Circuit Breaker |
| Product Type | CB |
| Rated Current ($I_n$) | 50 A |
| Rated Frequency (f) | 50 / 60 Hz |
| Rated Voltage ($U_r$) | 690 V |
| Rated Impulse Withstand Voltage ($U_{imp}$) | 8 kV |
| Rated Instantaneous Short-Circuit Current Setting ($I_i$) | 300…500 A |
| Rated Insulation Voltage ($U_i$) | 1000 V |
| Rated Operational Voltage | 690 V AC<br>500 V DC |
| Rated Service Short-Circuit Breaking Capacity ($I_{cs}$) | (220 V AC) 100 kA<br>(230 V AC) 100 kA<br>(240 V AC) 100 kA<br>(380 V AC) 70 kA<br>(415 V AC) 70 kA |

| | |
|---|---|
| | (440 V AC) 65 kA<br>(500 V AC) 50 kA<br>(525 V AC) 30 kA<br>(690 V AC) 15 kA<br>(250 V DC) 2 Poles in Series 70 kA<br>(500 V DC) 3 Poles in Series 70 kA |
| Rated Ultimate Short-Circuit Breaking Capacity ($I_{cu}$) | (220 V AC) 100 kA<br>(230 V AC) 100 kA<br>(240 V AC) 100 kA<br>(380 V AC) 70 kA<br>(415 V AC) 70 kA<br>(440 V AC) 65 kA<br>(500 V AC) 50 kA<br>(525 V AC) 30 kA<br>(690 V AC) 15 kA<br>(250 V DC) 2 Poles in Series 70 kA<br>(500 V DC) 3 Poles in Series 70 kA |
| Rated Uninterrupted Current ($I_u$) | 160 A |
| Release | TMA |
| Release Type | TM |
| Setting Range | 35...50 A |
| Short-Circuit Performance Level | H |
| Standards | IEC |
| Sub-type | XT2 |
| Terminal Connection Type | Fixed Circuit-Breakers |
| Version | F |

## Certificados y Declaraciones (Número de Documento)

| | |
|---|---|
| Data Sheet, Technical Information | 1SDC210100D0205<br>1SDC210099D0205 |
| Declaration of Conformity - CE | 9AKK106713A5901 |
| Environmental Information | 1SDL000190R0001 |
| GL Certificate | 1SDL000163R0093 |
| Instructions and Manuals | 1SDH000721R0001 |
| LR Certificate | 1SDL000163R0100 |

## Clasificaciones

| | |
|---|---|
| ETIM 4 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 5 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 6 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 7 | EC000228 - Power circuit-breaker for trafo/generator/installation protection |
| Object Classification Code | Q |
| UNSPSC | 39120000 |
| WEEE Category | 5. Small Equipment (No External Dimension More Than 50 cm) |

## Categorias

Productos y sistemas de baja tensión → Interruptores automáticos → Interruptores automáticos en caja moldeada → Tmax XT



