Indicating Valves, Butterfly or Ball Type

Design features provide a dependable visible indication of the open position even at a distance. If excessive force is applied to the handle, weakness-joints will break so as to preserve correct orientation between indicator and valve position. Valve and indicator parts are so designed that they can be assembled only one way, always to give correct indication. All FM Approved indicating valves turn clockwise to shut. They are small, lightweight, and, because of a resilient seat, are easy to operate. They are not subject to sticking or dropped gates. They are not recommended for throttling service. Unless otherwise noted in the listing, these valves have 175 psi (1205 kPa) rated working pressure.

VMT175S, VMW300, VMW300S, VML300, VML300S, VMG300, VMG300S

Model Number	*Product Type*	*Nominal Pipe Size, in*	*Maximum Working Pressure, psi (kPa)*	*Remarks*
VMT175S	Butterfly Valve, Threaded Ends	1, 1-1/4, 1-1/2, 2	175 (1205)	a, b, c, e
VMW300	Butterfly Valve, Wafer Body	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300 (2070)	b, c
VMW300S	Butterfly Valve, Wafer Body	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300 (2070)	a, b, c
VML300	Butterfly Valve, Lug Body	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300 (2070)	b, c, d
VML300S	Butterfly Valve, Lug Body	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300 (2070)	a, b, c, d
VMG300	Butterfly Valve, Grooved Ends	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 76.1, 139.7, 165.1 mm	300 (2070)	b, c
VMG300S	Butterfly Valve, Grooved Ends	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 76.1, 139.7, 165.1 mm	300 (2070)	a, b, c

Remarks:
a. Available with dual supervisory switches.
b. FM Approved for indoor and outdoor service.
c. FM Approved for aboveground installations only.
d. Flange standards ASME B16.1 Class 125, ASME B16.5 Class 150.
e. NPT or BSPT threads

Company Name:	AG FIRE SPRINKLER, S.L.
Company Address:	C/Alfoz De Bricia No 4, Pol Ind Villalonquejar, Burgos 09001, Spain
Company Website:	http://komtes.com
New/Updated Product Listing:	No
Listing Country:	Spain
Certification Type:	FM Approved
Primary Class of Work:	1112-Indicating Valves

© 2007-2018 FM Approvals. All rights reserved.