EC Declaration of Conformity

CE

The undersigned, representing the following:

Manufacturer: AG FIRE SPRINKLER S.L.
C/ Invención nº 11
P.I. Los Olivos 28906
Getafe – Madrid – SPAIN

Manufacturing Plant: C/ Merindad de Montija nº 9
P.I. Villalonquéjar 09001
Burgos – SPAIN

Herewith declares that the products **Model WM Water Motor Alarm,** are in conformity with the provisions of the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products regulation or CPR) when installed in accordance with the installation instructions contained in the product documentation, and that the **EN 12259-2:2000 including Amendments A1:2001, A2: 2005 and Corrigendum No.1** has been applied.

Provisions to which the product conforms: annex ZA of EN 12259-2:1999

Description of the product: - Rated working pressure: 12bar (175psi).
- For use with or without the Model H Retard Chamber.
- 3", 4" and 6" sizes for use in vertical or horizontal installations in automatic sprinkler systems.
- 8" sizes for use in vertical installations in automatic sprinkler systems.

Name and address notified certification body: FM Approvals Ltd., 1 Windsor Dials, Windsor, Berkshire, SL4 1RS, United Kingdom, notified under registration number 1725

Certificate number: 1725-CPD-F0014
Remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

NAME: Jose Ignacio Melgosa
POSITION: R & D & I Manager